

S.No. 512.....
Date .06/03/2024

PUBLIC HEALTH DEPARTMENT PHC PINDRA VARANASI UP
Water Quality Test Monitoring Report (Blanket and 15 Parameters) Month- March -2024

| Sl. No. | Panchayat | Village | Name of Habitation | Source | Sampling Date | Test Date | PH | Turb | EC | TDS | Th | Ca | Mg | Cl | Alka | Fe | NO3 | F | As | Total Coll | Remark Safe or Unsafe | |
|--|-------------------|-------------------|---|-------------|---------------|-----------|---------|------|-----|------|-----|-----|-------|------|------|-----|-----|------|-----|------------|-----------------------|-------------------------|
| | | | | | | | | | | | | | | | | | | | | | | Division Name :- Pindra |
| 01 | Saray Shekh Lourd | Saray Shekh Lourd | K. K. Chaturvedi Memorial Society Central Academy | Submersible | 05.03.24 | 06.03.24 | 7.6 | 2 | 664 | 432 | 198 | 32 | 11.52 | 20 | 260 | 0.4 | 0 | 0.62 | 0.0 | 0.0 | Safe | |
| 02 | | | | | | | | | | | | | | | | | | | | | | |
| 03 | | | | | | | | | | | | | | | | | | | | | | |
| 04 | | | | | | | | | | | | | | | | | | | | | | |
| 05 | | | | | | | | | | | | | | | | | | | | | | |
| 06 | | | | | | | | | | | | | | | | | | | | | | |
| 07 | | | | | | | | | | | | | | | | | | | | | | |
| 08 | | | | | | | | | | | | | | | | | | | | | | |
| 09 | | | | | | | | | | | | | | | | | | | | | | |
| 10 | | | | | | | | | | | | | | | | | | | | | | |
| 11 | | | | | | | | | | | | | | | | | | | | | | |
| 12 | | | | | | | | | | | | | | | | | | | | | | |
| 13 | | | | | | | | | | | | | | | | | | | | | | |
| 14 | | | | | | | | | | | | | | | | | | | | | | |
| 15 | | | | | | | | | | | | | | | | | | | | | | |
| 16 | | | | | | | | | | | | | | | | | | | | | | |
| Desirable Limit | | | | | | | 6.5-8.5 | 1.0 | | 500 | 200 | 75 | 30 | 250 | 200 | 0.3 | 45 | 1.0 | .01 | 0.0 | | |
| Permissible limit in absence of alternate source (IS 10500-2012) | | | | | | | NR | 5.0 | | 2000 | 600 | 200 | 100 | 1000 | 600 | 1.0 | NR | 1.5 | NR | | | |

Sample given by School Staff

Signature of Chemist/ *R. Prasad*
Lab Assistant

PHC Pindra Varanasi UP

Sana Datta
Principal

K.K Chaturvedi Memorial Society
Central Academy

Signature of Medical Officer *R. Prasad*
PHC Pindra Varanasi UP Officer

Prasad Kumar
Manager

Manager

K.K Chaturvedi Memorial Society
PHC Pindra Varanasi